



DISPLAY PURPOSES ONLY

**NOTES :**

1. ALL EXCAVATION AND REINSTATEMENT SHALL BE SUBJECT TO PRIOR APPROVAL BY TCC (CITIWORKS). THESE STANDARDS ARE FOR GENERAL USE BUT MAY BE ALTERED TO SUIT PARTICULAR LOCATIONS. THESE STANDARDS APPLY TO COUNCIL ROADS ONLY.
- \* 2. IN ALL ROADS THE BASE GRAVEL SHALL BE TO A DEPTH AT LEAST 75mm DEEPER THAN THE DEPTH OF THE EXISTING PAVEMENT WITH A MINIMUM DEPTH.
3. IN ALL ROADS THE ASPHALT SHALL BE TO A DEPTH AT LEAST 50mm DEEPER THAN THE EXISTING SEAL WITH A MINIMUM DEPTH.
4. CABLES TO BE IN DUCTS OR PROTECTED BY TILES OR TAPES AS APPLICABLE.
5. CRUSHER DUST MUST BE WATERED AND EITHER ROLLED OR TAMPED TO PROVIDE ADEQUATE COMPACTION AND TO BE SUBJECT TO COUNCIL INSPECTION BEFORE PLACEMENT OF ASPHALT.
6. GRAVEL OR SOIL AGGREGATE OF A QUALITY ACCEPTABLE TO THE COUNCIL MAY BE USED IN LIEU OF CRUSHER DUST IF WRITTEN TCC (CITIWORKS) PERMISSION IS OBTAINED. THESE MATERIALS MUST BE COMPACTIONED TO 95% STANDARD AASHO DENSITY.
7. BASE GRAVEL IS TO MEET QLD MAIN ROADS SPECIFICATION MRS11.05 12/99 TYPE 2.1 AND IS TO BE COMPACTIONED TO 100% STANDARD AASHO. ALL BASECOURSE GRAVEL IS TO BE SUBJECT TO COUNCIL INSPECTION AFTER COMPACTION AND PRIOR TO PLACEMENT OF ASPHALT. ON SEALED ROADS 2.1 BASE GRAVEL TO BE STABILISED WITH 1% CEMENT BY WEIGHT
8. ALL EXISTING ASPHALT SHALL BE NEATLY CUT WITH A DIAMOND SAW TO FORM THE EXCAVATION.



						ASSOCIATED DRAWINGS						<b>STANDARDS COUNCIL REQUIREMENTS FOR REINSTATEMENT OF STREET OPENINGS</b>					
						LEVEL DATUM	SV INDEX NO.										APPROVED
						-			-			DRN.	EJC				
						ERGON	TELSTRA	CAD INDEX NO.			MANAGER – CITIWORKS			SD.			
ZONE	REF.	REVISIONS	BY	CKD.	DATE				OPERATIONS ENGINEER			ENG.	DATE	M/FILM	SCALE	DRAWING NO.	A3
1													27/6/01		NTS	18614 A	