

From: "Town Planning" <townplanning@ergon.com.au>
Sent: Tue, 1 Jul 2025 13:13:07 +1000
To: "Development Assessment" <developmentassessment@townsville.qld.gov.au>
Cc: "Taryn Pace" <taryn.pace@townsville.qld.gov.au>;
"hello@northpointplanning.com.au" <hello@northpointplanning.com.au>; "Shelly Sharma"
<shelly.sharma@townsville.qld.gov.au>
Subject: RE: MCU25/0006 - 12-14 Waverly Lane DOUGLAS - Ergon Advice Agency
Response
Attachments: Ergon Referral Response - 12-14 Waverley Lane & 237-239 Riverside Boulevard,
Douglas .pdf

This Message Is From an External Sender

This message came from outside Townsville City Council. Please think carefully before clicking links or responding if you weren't expecting this email.

Dear Sir / Madam,

In relation to the above development application, please see attached Ergon Referral Response.

Should you have any queries, please do not hesitate to contact me.

Kind regards,

Harriet Veal
Town Planner

Property & Security Group | People, Property & Safety



Energy Queensland

Level 1, 26 Reddacliff Street, Newstead QLD 4006

M 0427 293 604

E harriet.veal@energyq.com.au

energyq.com.au



attachments) by an unintended recipient is prohibited. If you have received this email in error, please notify the sender by return email and destroy all copies of the original message. Any confidential or legal professional privilege is not waived or lost by any mistaken delivery of the email. Ergon Energy accepts no responsibility for the content of any email which is sent by an employee which is of a personal nature.

Sender Details:

Ergon Energy Corporation Limited | ABN 50 087 646 062

<http://www.ergon.com.au>

Ergon Energy policy is to not send unsolicited electronic messages. Suspected breaches of this policy can be reported by replying to this message including the original message and the word "UNSUBSCRIBE" in the subject.



420 Flinders Street, Townsville QLD 4810
PO Box 1090, Townsville QLD 4810
ergon.com.au

01 July 2025

Chief Executive Officer
City of Townsville

Attention: Taryn Pace

Via email: developmentassessment@townsville.qld.gov.au

cc Opulence Builders Group
c/- Northpoint Planning
Attention: Meredith Hutton
Via email: hello@northpointplanning.com.au

Dear Sir/Madam,

Ergon Advice Agency Response
Our Ref: ECM 25182680-25182691
Applicant Ref: NP24.257

This Referral Agency response is given under section 56 of the *Planning Act 2016*.

Response	
Outcome	Approved in full - subject to conditions
Referral assessment capacity	Advice
Matters referral assessment made against (S55(2))	The purpose of the <i>Electricity Act 1994</i> and <i>Electricity Safety Act 2002</i>
Reasons for decision (S56(7)(b))	<p>The works do not conflict with:</p> <ul style="list-style-type: none">the objectives set out within Part 2, Section 3 of the <i>Electricity Act 1994</i>the purpose of the <i>Electricity Safety Act 2002</i> as set out within Part 1 Division 2 Section 4 & 5. <p>The works do not adversely impact on the safe, efficient, and economically viable operation of the supply network.</p>

Have you seen our fact sheets?

See the 'considerations when developing around electricity infrastructure' section of our website
www.ergon.com.au/referralagency

Development Details	
Applicant	Opulence Builders Group
Assessment Manager	City of Townsville
Council Application No.	MCU25/0006
Street Address	12-14 Waverley Lane, Douglas QLD 4814 237-239 Riverside Boulevard, Douglas QLD 4814
RPD	Lot 999 SP 159422; Lot CP SP 177536
Development Type	Material Change of Use for Multiple Dwelling (34 Units)
Referral Trigger	<input type="checkbox"/> Schedule 10, Part 9, Division 2, Table 2, Item 1 (10.9.2.2.1) – Material Change of use of premises within 100m of a substation site or subject to an easement for the benefit of a distribution entity under the Electricity Act and the easement is for a supply network
Impacted Electrical Infrastructure	Easement D on SP169641 & Easement C on SP169640 – U/G 11kV Cable (ID: PA-04) & Low Voltage Cables

Ergon provides the following response to the application in accordance with Section 56(1) of the *Planning Act 2016*:

Component of Development	Advice Agency direction
MCU	<input type="checkbox"/> S56(1)(b)(i) – approval subject to stated development conditions

In accordance with Section 56(1) should the Assessment Manager decide to approve the proposed Development Application, as an Advice Agency, Ergon requires that the assessment manager impose the below conditions. These conditions have been imposed in response to the matters prescribed under Section 55 (2) of the *Planning Act 2016*.

Table 1			
Plans forming part of this Approval			
Title	Plan No.	Issue	Date
Site Plan	23-013 – Sheet sk_04	1	07/02/2025

Table 2			
Condition		Timing	Purpose/Reason
1	Carry out the approved development generally in	At all times	To ensure the development is

Have you seen our fact sheets?

See the 'considerations when developing around electricity infrastructure' section of our website www.ergon.com.au/referralagency

	<p>accordance with the approved plans and documents outlined within Table 1 of this approval and the following:</p> <ul style="list-style-type: none"> ▪ The specifications, facts and circumstances as set out in the development application submitted to Ergon; and ▪ Where a discrepancy or conflict exists between the written conditions of the approval and the approved plans, the requirements of the written conditions prevail 		carried out generally in accordance with the plans of development submitted within the application
2	Any alterations to the plans and document(s) identified within Table 1 of this response are to be resubmitted to Ergon for comment	At all times	To ensure the development is carried out generally in accordance with the plans of development submitted within the application
3	Comply with the terms of Easement D on SP169641 and Easement C on SP169640.	At all times	To ensure the safety and operation of Ergon's assets are maintained.

General Advice:

- Compliance with the Electrical Safety Act 2002, including any Code of Practice under the Act and the Electrical safety Regulation 2013 including any safety exclusion zones defined in the Regulation is mandatory

Have you seen our fact sheets?

See the 'considerations when developing around electricity infrastructure' section of our website www.ergon.com.au/referralagency

Should any doubt exist in maintaining the prescribed clearance to the overhead conductors and electrical infrastructure then the applicant is obliged under the Act to seek advice from Ergon.

- Any costs incurred by Ergon as a result of the works on the easement are to be met by the property Developer / owner.
- This response does not constitute an approval to commence any works within the easement. Consent to commence works relevant to the conditions of the easement is required. All works on easement (including but not limited to earthworks, drainage and detention basins, road construction, underground and overhead services installation) require detailed submissions, assessment, and consent (or otherwise) by Ergon.
- All works proposed to be undertaken in close proximity to overhead or underground electrical lines are to be undertaken in accordance with Ergon's Works Practice Manual WP1323. This document refers to various standards, guidelines, calculations, legal requirements, technical details, and other information relevant to working near high voltage infrastructure. A copy of WP1323 can be found online via Ergon's document library ([Document library | Ergon](#)).

Should you require any further information on the above matter, please contact Harriet Veal on 0427 293 604 or via email at townplanning@ergon.com.au.

Yours faithfully,

Harriet Veal

Harriet Veal
Town Planner

Have you seen our fact sheets?

See the 'considerations when developing around electricity infrastructure' section of our website www.ergon.com.au/referralagency